

**NOTICE OF SPILL FROM A WASTEWATER FACILITY**

A spill from a wastewater treatment or collection facility has occurred.

**INFORMATION ABOUT THE SPILL**

Facility Name: Salado Creek Water Recycling Center – 10137-008

Contact for further information: Anne Hayden – 210-233-3622

Location of the spill: 12-inch Sewer Main at 5603 Texoma Dr behind 3838 E Southcross Blvd

Estimated time and date of spill: December 17, 2022 at approximately 9:35 am

Estimated volume of the spill (number of gallons): Spill estimated > 100,000 gallons

Type of spill: (domestic) (industrial) (other) Explain other: Domestic wastewater

Area potentially affected: Salado Creek

Suspected cause of spill: Grease blockage in main

**THE FOLLOWING ACTIONS HAVE BEEN TAKEN:**

- Appropriate local governmental officials have been notified.
- TCEQ regional office has been notified.
- The spill has been contained.
- Increased monitoring of water supply systems has been initiated.
- The cause of the spill has been corrected.
- Clean-up activities are underway.
- Other: \_\_\_\_\_

**PERSONS MAY WISH TO TAKE THE FOLLOWING PERSONAL PRECAUTIONS**

- Use only water that has been distilled or boiled at a rolling boil for at least one minute for all personal uses including drinking, cooking, bathing and tooth brushing
- Don't swim in affected area streams, ponds or lakes.
- Always wash hands thoroughly before preparing or eating food.
- Always wash hands thoroughly after any contact with animals, soil or diapers.
- Private well owners may wish to treat their well water, have their well water tested and inspect their wells for proper siting, construction and maintenance.